

- 1 Waterproof Plug
- 2 IP66 Ingress Protection
- 3 Sealed Plug
- 4 Knob
- 5 Brand
- 6 ON
- 7 OFF



BYT-32



Accessories


## Application

**BENY** BYT Series DC Isolator Switch in plastic enclosure is applied 1~20KW Residential or Commercial Photovoltaic system, placed between photovoltage modules and inverters. Arcing time less than 3ms, that keep solar system more safe To ensure its stability and long service life, our products are made by components with optimum quality. Max voltage up to 1200V DC It holds a safe lead among similar products.

## Feature

- IP66 , UV Resistance
- Arcing Time < 3ms
- Earth Terminal
- IEC60947-3, AS60947.3
- 2 Pole, 4 Poles Available(Single | Double String)
- DC-PV2 / DC-21B: 32A up to 1200VDC

## Appearance Introduction



## Parameter

### Electrical Characteristics

Type	BYT-32, BYT-32M1, BYT-32M2 BYT.1-32, BYT.2-32
Function	Isolator, Control
Standard	IEC60947-3, AS60947.3
Utilization category	DC-PV2 / DC-21B
Pole	4P
Rated frequency	DC
Rated operational voltage ( $U_e$ )	600V, 800V, 1000V, 1200V
Rated operational current ( $I_e$ )	See the next page
Rated insulation voltage ( $U_i$ )	1200V
Conventional free air thermal current ( $I_{th}$ )	//
Conventional enclosed thermal current ( $I_{me}$ )	Same as $I_e$
Rated short-time withstand current ( $I_{cw}$ )	1kA, 1s (4, 4S, 4B); 1.7kA, 1s (2H)
Rated short-time making capacity ( $I_{cm}$ )	1.7kA, 1s (4, 4S, 4B); 3kA, 1s (2H)
Rated conditional short-circuit current ( $I_{cn}$ )	3kA
Rated impulsive withstand voltage ( $U_{imp}$ )	8.0kV
Overvoltage category	II
Suitability for isolation	Yes
Polarity	No polarity, "+" and "-" polarities could be interchanged.

### Service Life/Cycle Operation

Mechanical	20000
Electrical	2000

### Installation Environment

Ingress Protection	Enclosure	IP66
	Switch body	IP20
Storage Temperature	-5°C ~ +85°C	
Mounting Type	Vertically or horizontally	
Pollution degree	3	
Suitable environment	Outdoor / Indoor	

## BYT Series PV DC Isolator Switches

Identification	Rating data		
Switch, unenclosed - catalogue number (with DC-PV2 rating)	BYT.1-32, BYT.2-32		
Specific dedicated individual enclosure - catalogue number (with minimum IP56NW rating)	BYT-32 IP66NW		
Assembly of switch and specific dedicated individual enclosure - catalogue number	/		
$I_{th}$ rated thermal current, unenclosed, at 40°C shade ambient air temperature	32 amps		
$I_{the}$ rated thermal current, indoors, at 40°C shade ambient air temperature, in a specific dedicated enclosure	32 amps		
$I_{the}$ rated thermal current <u>outdoors</u> at 40°C shade ambient air temperature <u>without solar effects</u> in a specific dedicated enclosure rated IP66NW	32 amps		
$I_{the}$ solar current value outdoors at 60°C shade ambient air temperature (see D.8.3.11, table D3), with solar effects in a specific dedicated enclosure rated IP66NW	29 amps		
	$U_e$ rated operational voltage DC Volts	$I_e$ ; DC-PV2 rated operational current Amps	$I_{(make)}$ and $I_{c(break)}$ DC-PV2 4 x $I_e$ Amps
2 pole  ( <u>1</u> / <u>2</u> / <u>   </u> )	≤600	32	128
	800	32	128
	1000	13	52
	1200	13	52
4 pole  ( <u>1</u> / <u>2</u> / <u>3</u> / <u>4</u> / <u>   </u> )	≤600	32	128
	800	32	128
	1000	32	128
	1200	32	128

NOTE 1 The rating data in the table is example data, it is intended to be replaced by the relevant actual data.

NOTE 2 The ratings section of this table for  $U_e$ ,  $I_e$  and  $I_{(make)}$  and  $I_{c(breaker)}$  may have other number of poles or pole configurations than that shown, based on the test evidence obtained.

NOTE 3 The other data required in D.5.2.4 need not be in a table format.

# BYT Series PV DC Isolator Switches

## Wiring Diagram for Rated operational voltage $U_e$ (V) & Rated operational current $I_e$ (A)


Contacts wiring diagram	600V	800V	1000V	1200V	Poles in series	Number of Strings	Type Number	Weight kg/PCS
	32A	32A	13A	13A	2	2	4	0.70
	50A	45A	13A	13A	2	1	2H	0.70
	32A	32A	32A	32A	2	1	4B	0.70
	32A	32A	32A	32A	4	1	4S	0.70

## Switching Configurations


Type	4-pole	2-pole 4 Paralleled Poles	4-pole with Input and Output bottom	4-pole with Input on top Output bottom
/	4	2H	4B	4S
Contacts Wiring graph				
Switching example				

## Bridging links installation

installed incorrectly





installed correctly



\* Please note that all connections (including bridging link connections) should be tightening before energization.

## BYT Series PV DC Isolator Switches

### Terminals / connection

Type	BYT-32, BYT-32M1, BYT-32M2 BYT.1-32, BYT.2-32	
Number of poles	4-pole	
Terminal designation, main circuit	1; 3; 5; 2; 4; 6; 7; 8	
Type of terminal, main circuit	Screw terminal	
Rated cross section area, main circuit	4.0-16mm <sup>2</sup>	
Type of onductor		4-16mm <sup>2</sup> (Rigid: Solid or Stranded)
		4-10mm <sup>2</sup> (Flexible)
Number of conductors per terminal	1	
Required preparation of the conductor	Yes	
Stripping length (mm), main circuit	8mm	
Tightening torque (M4), main circuit	Min: 1.2Nm	
	Max: 1.8Nm	

### Dimensions(mm)

